

	Document Title:	Doc No:	FRM B1-02	
	Structural Performance Certification Authorization Report	Rev No: 6	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 606 - 101.0
 Issue Date: 12/31/2008
 Revision Date: 12/31/2008
 Expiration Date: 11/25/2012
 Company Code: 606

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product qualification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
Upstate Door, Inc. 26 Industrial Street Warsaw NY 14569	Model: Double IS Impact SHD w/Sidelite Mull Ass'y XX/O Operator Type: SHD Config: No, GS-5/16" Lami IG Max Width: 111 Max Height: 99

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG 50-Size Tested 2819x2502(111x99)-Type LWSHC

Qualifying Test Information:	
Test Report No:	ATI-85665.01-109-44
Test Report Expiration:	11/25/2012

Authorized Signature:

Keystone Certifications, Inc.
 1790 Old Trail Road, Suite D
 Etters, Pennsylvania 17319
 Phone: 717-932-8500
 Fax: 717-932-8501